



METER INSTALLATION NOTE:

**GAS METERS WILL NOT BE INSTALLED UNTIL SPECIFICATIONS ARE MET,
PROPERTY OWNER/CONTRACTOR RESPONSIBLE FOR COMPLIANCE.**

STUB-OUT SPECIFICATIONS:

1. STUB-OUTS TO EXTEND 2" TO 4" BEYOND THE FINISHED WALL.
2. REVERSE LAYOUT FOR THE RIGHT SIDE GAS RISER.
3. MAXIMUM OF 40 METERS IN ONE HEADER.
4. WHERE POSSIBLE, RACK METERS ONLY TWO ROWS HIGH.
5. IF HOUSE METER IS OVER 400 C.F.H., IT CANNOT BE INCLUDED IN THE HEADER.
6. USE BRASS TAGS ON EACH HOUSE LINE WITH UNIT NUMBERS OF ADDRESS.
7. GAS SERVICE RISER SHALL BE 10" FROM THE FACE OF THE BUILDING, WALL, FENCE, ETC.
FOR METER CABINET REQUIREMENTS, SEE STANDARD DRAWING A-990 (SD-A-990).